



Type Approval - Electrical

Approval Number	EL 00024
Manufacturer	Olex New Zealand Limited
Manufacturing Plant	69 Paraitē Road, Bell Block, New Plymouth, New Zealand
Product Description	Olex Marketing Code XNNP28RWF01 – 1 Conductor 400 mm ² stranded compacted plain annealed copper, semi-conductive conductor screen (0.3 mm min wall), 19/33 kV TR-XLPE insulated (8.0 mm nom wall), Strippolex insulation screen (0.6 mm min wall), helical copper screened (area 90 mm ² min suitable for 13.5 kA for 1 sec fault level), PVC (5V-90) sheathed (2.0 mm min wall), HDPE sheathed (2.0 mm min wall), to AS/NZS 1429.1 and TfNSW Standards T HR EL 20001 ST incorporating optical fibres in loose tube A3C147PL2/2/2BK.
Approved for	Applications in accordance with T HR EL 20001 ST

Conditions

Approved:

Date: 19/12/2014

Neal Hook

Lead Electrical Engineer