



## Type Approval - Electrical

<b>Approval Number</b>	EL 00025
<b>Manufacturer</b>	Olex New Zealand Limited
<b>Manufacturing Plant</b>	69 Paraitē Road, Bell Block, New Plymouth, New Zealand
<b>Product Description</b>	Olex Marketing Code XJNP26RW003 – 3 Conductors 240 mm <sup>2</sup> stranded compacted plain annealed copper, semi-conductive conductor screen (0.3 mm min wall), 6.35/11 kV TR-XLPE insulated (3.4 mm nom wall), Strippolex insulation screen (0.6 mm min wall), helical copper wire screened (suitable for 13.4 kA for 1 sec fault level), laid up with non-hygroscopic fillers, PVC (5V-90) sheathed (2.0 mm min wall), HDPE sheathed (2.0 mm min wall), to AS/NZS 1429.1 and TfNSW Standards T HR EL 20001 ST.
<b>Approved for</b>	Applications in accordance with T HR EL 20001 ST

### Conditions

Approved:

Date: 19/12/2014

---

Neal Hook

Lead Electrical Engineer