



Type Approval - Electrical

Approval Number	EL 00033
Manufacturer	Raychem (TE Connectivity)
Manufacturing Plant	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
Product Description	Raychem ESD-6680-AU-2/15 – Joint for transitions from screened 33kV single core polymeric insulated cables, conductor diameter 500mm ² to screened 33kV 3 core polymeric insulated cable, conductor diameter 150-300mm ² , without DTS FO.
Approved for	Transition from 33kV 3 core cables to single core cables complying with T HR EL 20001 ST
Conditions	Joint kit shall be installed by staff that are Accredited Cable Jointers in accordance with RailSafe document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP sections 4.2 and 5.5.

Approved:

Date: 12/3/2015

Neal Hook

Lead Electrical Engineer