



PTA EL 111/2017

Product Type Approval Certificate

This certificate is issued to:

Supplier:	Transformers Manufacturing Company Pty Ltd
	19 Ewing St, Brunswick, Victoria 3056

In respect of:

Manufacturer:	Transformers Manufacturing Company Pty Ltd
Place of manufacture:	19 Ewing St, Brunswick, Victoria 3056
Product description:	Rectifier transformer, 66kV/600V/600V, 5.35MVA, ONAN, 66kV cable connected, with off-circuit tapchanger in accordance with ASA standard EP 03 01 40 00 SP (version 3.1).
Use approved for:	Use on the RailCorp 66kV network in traction substations with 12 pulse series bridge rectifiers.
Conditions of approval:	Type approval is valid for the rectifier transformer as detailed on the following set of general drawings (all rev A) EL0560108 – EL0560116.
Limitations:	N/A
Comments:	N/A

Approval

ASA Lead Engineer:	Chris Lilly, Asset Standards Authority
Position:	A/Lead Electrical Engineer
Contact details:	chris.lilly@transport.nsw.gov.au
Signature:	
Date:	9 th January 2019

Independent safety assessor:	N/A
Position:	
Contact details:	
Signature:	
Date:	