

Product Type Approval Certificate

Full

This certificate is issued to:

Supplier name and address:	TE Connectivity Australia Pty. Ltd. Suite 501, Level 5/3 Thomas Holt Dr, Macquarie Park NSW 2113, Australia
-----------------------------------	--

In respect of:

Manufacturer:	Tyco Electronics Raychem GmbH
Place of manufacture:	Finsinger 1 Feld 85521 Ottobrunn, Germany
Product description:	Raychem ESD-4870-AU-1/24-EPKT – Termination for 1.5 kV Single core polymeric insulated cables with and without insulation screen and composite sheath, 240 mm ² – 400 mm ²
Use approved for:	1500V DC cables, as per T HR EL 2005 ST and T HR EL 2004 ST
Conditions of approval:	Termination kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 Personnel Certifications – Electrical, and trained by TE Connectivity in accordance with the requirements of T HR EL 2005 ST and T HR EL 2004 ST.
Limitations:	Nil

Evaluating rail transport operator

Name:	Lidija Dumbaloska
Position:	Director Energy Networks & Systems, Asset Management Branch, Transport for NSW
Signature:	<i>L Dumbaloska</i>
Date:	24/04/2024

Independent safety assessor

Name:	
Position:	
Signature:	
Date:	

Independent technical reviewer

Name:	
Position:	
Signature:	
Date:	

Product approval pack reference number: FT745704