

# Product Type Approval Certificate

*Full*

This certificate is issued to:

<b>Supplier name and address:</b>	Raychem (TE Connectivity) Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
-----------------------------------	---

In respect of:

<b>Manufacturer:</b>	Raychem (TE Connectivity)
<b>Place of manufacture:</b>	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
<b>Product description:</b>	Raychem ESD-8592-11/21 – 33 kV Transition joint for 1-core polymeric insulated cables with wire screen and composite sheath, 500-630 mm <sup>2</sup>
<b>Use approved for:</b>	33 kV Transition joint for 1C (500 mm <sup>2</sup> – 630 mm <sup>2</sup> ) XLPE cables, complying with T HR EL 20001 ST
<b>Conditions of approval:</b>	Termination kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP
<b>Limitations:</b>	NA

## Evaluating rail transport operator

<b>Name:</b>	Lidija Dumbaloska
<b>Position:</b>	Director Energy Networks and Systems, Asset Management, Transport for NSW
<b>Signature:</b>	<i>L. Dumbaloska</i>
<b>Date:</b>	10/12/2021

**Product approval pack reference number:** fA1479967