

## Product Type Approval Certificate

### Restricted

This certificate is issued to:

<b>Supplier name and address:</b>	Schneider Electric Australia Pty. Ltd 78 Waterloo Road, Macquarie Park, New South Wales 2113
-----------------------------------	-------------------------------------------------------------------------------------------------

In respect of:

<b>Manufacturer:</b>	Schneider Electric
<b>Place of manufacture:</b>	14 8ème Rue, 06510 Carros, France
<b>Product description:</b>	Schneider VIP 400 (REL59915) Protection Relay: <ul style="list-style-type: none"> <li>• Self-powered</li> <li>• Uses phase current sensors instead of conventional CTs</li> <li>• No test block required</li> </ul>
<b>Use approved for:</b>	Approved for use in the TAHE Electrical 11kV network.
<b>Conditions of approval:</b>	N/A
<b>Limitations:</b>	This protection relay is to be used with non-SCADA controlled 11kV switchgear where no auxiliary supply is available.

### Evaluating rail transport operator

<b>Name:</b>	Mo Mansour
<b>Position:</b>	Director Energy Networks & Systems, Asset Management Branch, Transport for NSW
<b>Signature:</b>	<i>Mmansour</i>
<b>Date:</b>	29/8/2022

**Product approval pack reference number: fT1268333**